



**PLANTA POTABILIZADORA PASTOR LOZANO**

**ANÁLISIS FÍSICOQUÍMICOS  
 AGUA CRUDA RIO BRAVO  
 JUNIO 2024**

**RESULTADOS EN MG/LT**

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	PROMEDIO
TURBIEDAD N.T.U.	21.1	21.5	19.1	23.3	20.0	17.2	15.0	13.7	15.8	19.0	20.1	15.8	15.7	16.0	13.5	14.8	11.0	5.8	6.7	6.7	15.6
P.H.	7.0	7.6	7.8	7.4	7.4	7.4	7.5	7.4	7.3	7.4	7.8	7.5	7.0	7.3	7.5	7.2	7.9	7.1	7.7	7.7	7.4
ALCALINIDAD TOTAL	102	107	110	90	91	95	95	119	108	110	104	88	90	99	93	112	111	112	100	114	103
DUREZA TOTAL	264	272	250	238	245	252	250	264	259	249	260	250	260	255	265	295	300	306	330	320	269
DUREZA DE CALCIO	167	171	140	146	151	145	150	140	158	145	140	139	130	147	146	180	188	186	199	185	158
DUREZA DE MAGNESIO	97	101	110	92	94	107	100	124	101	104	120	111	130	108	119	115	112	120	131	135	112
CLORUROS	154	137	133	120	140	133	137	140	143	135	133	120	140	130	125	182	175	192	188	200	148
SDT	685	517	590	501	512	527	489	487	489	459	565	536	530	509	493	607	634	620	608	598	548
TEMPERATURA °C	27.7	27.6	28.3	27.2	28.6	28.7	26.5	27.8	27.6	28.5	24.7	27.5	26.2	25.4	26.9	24.4	26.8	27.5	27.8	28.3	27.2

AUTORIZÓ:

*Edna MARISSA SOTO LOZANO*  
 IQ. EDNA MARISSA SOTO LOZANO  
 JEFA DE LABORATORIO

V6.Bo.

*Guillermo NAVA LUJANO*  
 BIÓLOGO GUILLERMO NAVA LUJANO  
 COORDINADOR DE CALIDAD DEL AGUA

*Merdy*