



PLANTA POTABILIZADORA PASTOR LOZANO

**ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA RÍO BRAVO
 JULIO 2024**

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	31	PROMEDIO
TURBIEDAD N.T.U.	8.4	9.3	10.4	11.8	12.3	10.0	10.8	10.4	10.5	8.4	10.9	12.5	9.6	10.6	10.2	9.6	10.0	8.9	13.2	12.3	11.7	10.5	12.9	10.7
P.H.	7.5	7.7	8.1	7.6	7.6	7.5	7.3	7.0	7.9	8.0	7.0	7.8	7.0	6.8	7.9	7.9	7.1	7.5	7.4	7.6	7.6	7.4	7.5	7.5
ALCALINIDAD TOTAL	91	102	95	98	92	118	107	110	116	120	135	147	127	135	120	90	92	95	87	93	117	116	92	108
DUREZA TOTAL	375	323	375	360	335	367	356	361	379	416	430	404	432	353	320	256	236	260	240	244	257	297	265	332
DUREZA DE CALCIO	207	202	190	208	190	200	231	220	247	265	215	243	255	225	178	150	130	150	110	135	140	119	136	189
DUREZA DE MAGNESIO	168	121	185	152	145	167	125	141	132	151	215	161	177	128	142	106	106	110	130	109	117	178	129	143
CLORUROS	202	209	287	232	229	218	244	242	240	263	327	299	289	265	221	160	175	146	148	155	151	165	151	218
SDT	640	641	814	761	991	889	853	851	827	834	990	997	934	843	702	535	520	670	657	665	630	609	595	759
TEMPERATURA °C	25.4	25.3	27.3	27.7	29.3	26.3	26.5	26.9	24.8	27.0	28.4	28.7	28.3	29.0	28.7	26.3	27.5	26.1	27.0	26.0	26.0	28.2	28.0	27.2

AUTORIZÓ:

Vo.Bo.

Edna Soto Lozano
 IQ. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Guillermo Nava Lujano
 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA