



PLANTA POTABILIZADORA PASTOR LOZANO

**ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA CANAL RODHE**

JULIO 2024

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	31	PROMEDIO
TURBIEDAD N.T.U.	33.4	45.2	26.1	39.4	37.8	42.9	53.4	28.5	38.8	21.0	14.6	16.8	23.7	23.7	15.8	26.5	24.5	19.7	17.6	30.3	42.2	25.7	30.6	29.5
P.H.	7.7	7.8	7.5	8.0	8.1	7.1	7.2	7.0	7.7	8.1	7.1	8.0	7.0	8.1	7.7	7.3	7.3	7.4	7.4	7.6	7.5	7.3	7.5	7.5
ALCALINIDAD TOTAL	98	95	110	92	85	83	105	84	87	130	120	140	145	120	117	122	88	97	83	86	116	107	97	105
DUREZA TOTAL	366	458	338	460	450	410	344	395	407	414	420	455	446	414	387	280	250	290	267	256	267	259	241	360
DUREZA DE CALCIO	211	228	193	257	184	269	208	194	235	253	252	271	262	236	228	167	150	155	131	120	148	148	120	201
DUREZA DE MAGNESIO	155	230	145	203	266	141	136	201	172	161	168	184	184	178	159	113	100	135	136	136	119	111	121	159
CLORUROS	233	284	222	287	288	280	202	252	251	264	239	320	303	318	324	212	124	162	172	152	150	145	165	233
SDT	698	803	686	928	990	998	796	859	854	852	928	940	989	993	953	651	581	788	701	633	620	592	570	800
TEMPERATURA °C	26.6	25.3	27.8	27.5	29.2	26.7	26.5	26.9	24.8	26.8	29.5	28.6	28.1	28.8	28.5	27.0	27.4	25.8	27.0	25.6	26.1	28.5	28.1	27.3

AUTORIZÓ:

Edna Marissa Soto Lozano
 IQ. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Ver.Bo.

 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA