




PLANTA POTABILIZADORA PASTOR LOZANO

**ANALISIS FISICOQUÍMICOS
 AGUA CRUDA RIO BRAVO
 AGOSTO 2024**

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	PROMEDI O
TURBIEDAD N.T.U.	12.3	10.3	10.2	11.1	8.9	9.2	9.4	11.8	10.5	14.0	16.1	18.3	21.3	16.6	15.9	15.7	16.6	13.9	11.0	12.9	17.1	16.3	13.6
P.H.	7.3	7.3	7.4	7.4	7.4	7.5	7.3	7.0	7.0	7.7	7.4	7.5	7.4	7.3	7.4	7.4	7.4	7.4	7.4	7.5	7.5	7.5	7.4
ALCALINIDAD TOTAL	100	92	110	110	90	97	90	109	107	100	94	95	92	94	95	98	95	104	90	92	90	100	97
DUREZA TOTAL	270	255	250	231	228	239	235	245	260	270	268	255	250	248	245	232	225	220	227	248	246	259	246
DUREZA DE CALCIO	150	130	136	140	148	150	135	146	157	120	125	120	100	115	133	129	140	128	136	140	138	156	135
DUREZA DE MAGNESIO	120	125	114	91	80	89	100	99	103	150	143	135	150	133	112	103	85	92	91	108	108	103	111
CLORUROS	161	164	161	154	136	137	132	137	142	170	161	135	165	107	114	106	109	111	105	119	117	127	135
SDT	582	571	534	507	469	444	593	578	598	604	548	475	405	551	482	462	445	425	419	417	415	556	504
TEMPERATURA oC	27.7	27.0	28.0	27.9	28.2	29.7	29.2	24.2	28.7	28.1	29.5	28.6	28.1	29.6	27.7	29.0	28.7	28.4	29.0	29.4	28.7	28.9	28.4

AUTORIZÓ:


 IQ. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Vo.Bo.


 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA