



**PLANTA POTABILIZADORA PASTOR LOZANO**

**ANÁLISIS FÍSICOQUÍMICOS  
 AGUA CRUDA CANAL RODHE  
 AGOSTO 2024**

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	PROMEDI O
TURBIEDAD N.T.U.	22.8	17.4	16.1	18.2	43.3	13.8	27.8	24.9	28.4	15.5	32.3	30.6	33.2	19.9	20.0	45.5	58.8	46.7	33.6	36.8	55.4	20.0	30.0
P.H.	7.2	7.1	7.1	7.1	7.6	7.6	7.7	7.1	7.1	7.9	7.8	7.6	7.2	7.4	7.2	7.1	7.2	7.3	7.2	7.3	7.3	7.2	7.3
ALCALINIDAD TOTAL	109	103	114	117	98	99	110	96	100	97	95	115	128	118	110	99	130	107	98	91	100	110	107
DUREZA TOTAL	265	258	239	245	257	270	250	239	259	245	273	235	231	259	266	255	250	249	252	269	247	275	254
DUREZA DE CALCIO	150	128	110	140	145	159	132	140	142	130	157	140	132	156	167	160	138	133	150	151	125	178	144
DUREZA DE MAGNESIO	115	130	129	105	112	111	118	99	117	115	116	95	99	103	99	95	112	116	102	118	122	97	110
CLORUROS	163	172	170	162	163	165	177	141	132	155	142	165	157	141	140	133	147	153	130	148	138	184	154
SDT	587	593	575	554	532	521	600	582	585	543	535	544	512	601	584	568	555	515	484	487	467	610	552
TEMPERATURA oC	27.7	27.3	28.5	28.1	28.4	29.7	29.1	25.4	28.7	28.3	29.5	28.6	28.3	28.0	27.8	28.8	28.7	28.8	28.7	29.0	28.4	28.7	28.4

AUTORIZÓ:

**IQ. EDNA MARISSA SOTO LOZANO**  
 JEFA DE LABORATORIO

Vo.Bo.

**BIÓLOGO GUILLERMO NAVA LUJANO**  
 COORDINADOR DE CALIDAD DEL AGUA

*Im e Dr*