



PLANTA POTABILIZADORA PASTOR LOZANO



COMAPA
COMISIÓN MUNICIPAL DE AGUA POTABLE Y
ALCANTARILLADO DEL MUNICIPIO DE REYNOSA
REYNOSA, TAMPAULIPAS

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA CANAL RODHE
SEPTIEMBRE 2024

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	17	18	19	20	23	24	25	26	27	30	PROMEDIO
TURBIEDAD N.T.U.	22.1	12.0	20.2	34.1	11.3	25.3	16.0	42.3	16.8	26.9	50.0	18.6	12.6	33.4	21.5	16.8	19.8	12.9	17.6	17.7	22.4
P.H.	7.3	7.3	7.2	7.1	7.1	7.1	7.3	7.1	7.0	7.0	7.0	7.2	7.5	7.5	7.8	6.8	7.7	7.6	7.7	7.6	7.3
ALCALINIDAD TOTAL	100	99	92	98	99	110	109	105	95	104	109	94	99	97	92	99	96	99	100	102	100
DUREZA TOTAL	257	276	270	265	258	279	266	278	260	247	270	246	248	250	255	257	277	263	279	251	263
DUREZA DE CALCIO	155	169	146	130	132	175	160	155	144	135	149	138	145	150	140	133	160	155	163	138	149
DUREZA DE MAGNESIO	102	107	124	135	126	104	106	123	116	112	121	108	103	100	115	124	117	108	116	113	109
CLORUROS	131	126	120	128	125	120	128	130	128	130	138	120	122	128	122	130	132	120	127	136	127
SDT	530	516	465	455	458	535	494	514	458	478	484	456	455	449	436	517	520	550	558	543	493
TEMPERATURA °C	29.0	27.9	27.9	27.2	28.2	26.5	24.0	25.9	27.3	28.1	24.0	26.2	26.7	28.3	25.8	28.9	21.2	21.1	25.7	26.7	26.3

AUTORIZÓ:

IQ. ANDREA RODRÍGUEZ AGUILAR
ENCARGADA DE LABORATORIO

Ver.Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA